



Canby Fire District
221 S. Pine Street
Canby, Oregon 97013
(503) 266-5851

Fire Protection Systems Inspection, Testing, and Maintenance Schedules

Fire Alarm Systems Testing and Inspection Schedule

As per **NFPA 72 (National Fire Alarm and Signaling Code)** all component parts of your fire alarm system shall be inspected regularly.

Here's a limited inspection schedule:

- **Weekly:** control panels; power supplies; fuses; LEDs, trouble signals (for unmonitored alarms)
- **Monthly:** batteries and other power sources; verify central station is receiving signals
- **Semi-annually:** verify remote annunciators are functioning, battery load voltage test
- **Annually:** Review of all fire components and equipment including functional tests of smoke detectors and other initiating devices as well as notification appliances and other associated equipment by a licensed contractor.
- **Every five years:** Zoned fire alarm system smoke detectors shall be sensitivity tested. Addressable smoke detectors can be verified through fire panel programming by a licensed contractor.



Your facility may have additional systems in need of certification by a fire protection company. Discuss your needs with your fire protection contractor or contact Canby Fire District for more information.

***To gain additional information, or for questions,
please contact our Fire Inspector at: (503) 592-4695.***

Canby Fire District is committed to creating safer communities through prevention, preparedness, and effective fire and medical emergency response.