



**Canby Fire District**  
221 S. Pine Street  
Canby, Oregon 97013  
(503) 266-5851

## Fire Protection Systems Inspection, Testing, and Maintenance Schedules

### Emergency/Exit Lighting Testing and Inspection Schedule

NFPA 101 (*Life Safety Code*) set standards to ensure proper exit sign and emergency lighting placement, visibility, and performance in various settings.

- **Monthly:** Visual 30 second inspection. This can be done by the property owner by pressing the 'test' button on the unit.
- **Annually:** 90-minute load testing by qualified person. Emergency back-up batteries shall be replaced at intervals set by the manufacturer, or when light fails to continually illuminate for the full 90-minutes.



***Your facility may have additional systems in need of certification by a fire protection company. Discuss your needs with your fire protection contractor or contact Canby Fire District for more information.***

***To gain additional information, or for questions,  
please contact our Fire Inspector at: (503) 592-4695.***